369987b 1 01.30.18

#### Caséta® Wireless Load Controls


The Caséta<sub>®</sub> Wireless family of Dimmers and Switches can be controlled directly and remotely when paired with Pico<sub>®</sub> Remote Controls providing a system that delivers convenience and ease of installation.

Caséta<sub>®</sub> Wireless Dimmers and Switches use Lutron<sub>®</sub> patented Clear Connect<sub>®</sub> RF Technology which enables wireless communication with Pico<sub>®</sub> Remote Controls and the Lutron<sub>®</sub> Smart Bridge and Smart Bridge PRO.


#### **Features**

- Works with Pico<sub>®</sub> Remote Control
- Works with the Lutron<sub>®</sub> App (via a Smart Bridge or Smart Bridge PRO)<sup>1</sup>
- Lutron<sub>®</sub> patented Clear Connect<sub>®</sub> RF Technology works through walls and floors
- Includes Front Accessible Service Switch (FASS™) for safe lamp replacement
- Works with Lutron<sub>®</sub> Radio Powr Savr<sub>™</sub> Occupancy and Vacancy Sensors in standalone applications (sensors do not work with Smart Bridge or Smart Bridge PRO)


#### Caséta<sub>®</sub> Wireless In-Wall Switches




# Caséta<sub>®</sub> Wireless In-Wall Dimmers



Caséta<sub>®</sub> Wireless ELV+ Dimmer



Caséta<sub>®</sub> Wireless Plug-In Lamp Dimmer



Note: Certain models or load types will require a neutral connection. (see Load Types and Capacity sections)

#### **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

The Lutron<sub>®</sub> App is required for setup and usage with the Smart Bridge and Smart Bridge PRO. The Lutron<sub>®</sub> App is compatible with iOS<sub>®</sub> devices version 8.0 or later and Android<sub>™</sub> devices 4.0 or later.
iOS is a registered trademark of Cisco in the U.S. and other countries and is used under license.
Android is a trademark of Google Inc.

369987b 2 01.30.18

## **Specifications**

#### **Regulatory Approvals**

- cULus Listed
- NOM Certified
- FCC Approved. Complies with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules
- Industry Canada Certified
- IFTEL Certified
- NEMA 410 (-5ANS, -6ANS, -5WS, -10NXD, -5NE)

#### **Power**

Operating voltage:

- 120 V~ 50/60 Hz: -3PCL, -6WCL, -10NXD, -6ANS, -5ANS, -5NE
- 120/277 V∼ 50/60 Hz: -5WS-DV

#### **Key Design Features**

- Tested to withstand electrostatic discharge without damage or memory loss, in accordance with IEC 61000-4-2.
- Tested to withstand surge voltages without damage or loss of operation, in accordance with IEEE C62.41-1991 Recommended Practice on Surge Voltages in Low-Voltage AC Power Circuits.
- Load controls always operate locally and do not require system control.
- Power failure memory: should power be interrupted, the control will return to its previously set level prior to the interruption when power is restored.
- PD-5WS-DV, PD-5ANS, PD-6ANS, and PD-10NXD use conventional 3-way wiring.
- Uses Lutron<sub>®</sub> Claro<sub>®</sub> Wallplates or designer-style wallplates from other manufacturers. Wallplates are sold separately.
- Lutron<sub>®</sub> Claro<sub>®</sub> Wallplates snap on with no visible means of attachment.
- Requires a 1-gang U.S. wallbox. 3½ in (89 mm) depth recommended, 2¼ in (57 mm) depth minimum.
- Green status LED(s) to indicate load status.

Job Number:

#### System Communications and Capacity

- Caséta<sub>®</sub> Wireless In-Wall Switches and Dimmers communicate with Pico<sub>®</sub> remote controls and the Lutron<sub>®</sub> Smart Bridge/Smart Bridge PRO through Radio Frequency (RF).
- The Caséta<sub>®</sub> Wireless In-Wall Switches and Dimmers communicate with Lutron<sub>®</sub> Radio Powr Savr<sub>™</sub>
   Occupancy and Vacancy Sensors in a standalone application. Sensors do not work with Smart Bridge or Smart Bridge PRO.
- The Caséta<sub>®</sub> Wireless In-Wall Switches and Dimmers must be located within 60 ft (18 m) line-of-sight or 30 ft (9 m) through walls, of Pico<sub>®</sub> remote controls and Lutron<sub>®</sub> Smart Bridge devices.

#### **Device limits**

- Pico<sub>®</sub> Remote Controls and Radio Powr Savr<sub>™</sub>
   Occupancy Sensors: up to 10 devices (total) may be paired to each Caséta<sub>®</sub> Wireless In-Wall Switch/ Dimmer (with no Smart Bridge installed).
- Smart Bridge or Smart Bridge PRO system: up to 50 total wireless devices (Caséta<sub>®</sub> Wireless Dimmers/ Switches, Pico<sub>®</sub> Remote Controls, and Shades) are supported per system. Smart Bridge or Smart Bridge PRO counts as one device.

#### Environment

- Ambient operating temperature: 32 °F to 104 °F (0 °C to 40 °C), 0% to 90% humidity, non-condensing. Indoor use only.
- PD-5WS-DV, PD-5ANS, PD-6ANS, and PD-10NXD can be used with mechanical switch in 3-way applications.

	WESTIGHT OF ESTIMATION CODMITTAL		1 agc
	Job Name:	Model Numbers:	
ı			

## **LUTRON** SPECIFICATION SUBMITTAL

369987b 3 01.30.18

## **Features**

	PRO Dimmer PD-10NXD	Plug-In Dimmer PD-3PCL	In-Wall Dimmer PD-6WCL	ELV+ Dimmer PD-5NE	2-wire Switch PD-5WS-DV	Neutral Switch PD-5ANS, PD-6ANS
Simple two-wire installation (no neutral wire required)	√1		V		7	
Capable of dimming loads	√	√	√	<b>√</b>		
Favorite button (user defined one touch light level)				V		
Works with Hi-lume <sub>®</sub> 1% 2-Wire LED Drivers (Forward-phase only)	V			V	V	V
Works with Power Interfaces (PHPM and GRX TVI)	V			V		
Works with Power Interfaces (PHPM-SW)						√
No wiring required		√				

# **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

 $<sup>^{\</sup>rm 1}$   $\,$  In some low-wattage applications the PD-10NXD will require a neutral wire connection.

369987b 4 01.30.18

# Load Type and Capacity - Switches

Madal Number	December	Valta a a	Load Type Minimum Load			Maximum Load <sup>3</sup>	3
Model Number	Description	Voltage	Load Type	Nillillillillillillillillillillillillill	Not Ganged	End of Gang	Middle of Gang
		120 V~	Incandescent/ Halogen	25 W	600 W	450 W	350 W
		277 V∼	Incandescent/ Halogen	25 W	1350 W	1100 W	800 W
		120 V∼	MLV	25 W	600 VA/475 W	450 VA/350 W	350 VA/275 W
	Two-wire	277 V∼	MLV	25 W	1350 VA/1075 W	1100 VA/875 W	800 VA/625 W
PD-5WS-DV <sup>1</sup>	switch	120 V∼	General Purpose Fan	0.4 A	3 A	3 A	3 A
		120/277 V∼	LED	Use LUT-MLC <sup>2</sup>	5 A	4 A	3 A
		120/277 V∼	Fluorescent	Use LUT-MLC <sup>2</sup>	5 A	4 A	3 A
		120 V∼	ELV	Use LUT-MLC <sup>2</sup>	600 W	450 W	350 W
		277 V∼	ELV	Use LUT-MLC <sup>2</sup>	1350 W	1100 W	800 W
	Neutral-wire	120 V~	Incandescent/ Halogen	10 W	600 W	600 W	600 W
			MLV	10 W	600 VA	600 VA	600 VA
DD 54110	switch		Fan	0.1 A	3 A	3 A	3 A
PD-5ANS	(neutral connection		LED	1 bulb	5 A	5 A	5 A
	required)		Fluorescent	1 ballast	5 A	5 A	5 A
			ELV	10 W	600 W	600 W	600 W
			PHPM-SW	1 interface	2 interfaces	2 interfaces	2 interfaces
			Incandescent/ Halogen	10 W	720 W	720 W	600 W
	Neutral-wire		MLV	10 W	720 VA	720 VA	600 VA
DD CANO	switch	400 1/	Fan	0.1 A	3.6 A	3.6 A	3.6 A
PD-6ANS	(neutral connection	120 V∼	LED	1 bulb	6 A	6 A	5 A
	required)		Fluorescent	1 ballast	6 A	6 A	5 A
			ELV	10 W	720 W	720 W	600 W
			PHPM-SW	1 interface	3 interfaces	3 interfaces	3 interfaces

<sup>&</sup>lt;sup>1</sup> No neutral wire required.

#### **LUTRON** SPECIFICATION SUBMITTAL

Job Number:

Job Number:

Page	Э
------	---

To ensure proper operation of the switch with LED, fluorescent, and ELV loads, a LUT-MLC may be required, especially at lower wattages. If the status LED on the switch is flashing or solid red in color, a LUT-MLC must be installed. To guarantee best performance, installing a LUT-MLC with these load types regardless of wattage is recommended. Rarely, some load types may still flicker or glow in the off state even with the LUT-MLC installed, in which case a different load may be required or more than one LUT-MLC is required.

<sup>&</sup>lt;sup>3</sup> See "Ganging and Derating" section.

369987b 5 01.30.18

# Load Type and Capacity - Dimmers

Madal Number	Description	Voltogo	Load Type	Minimum		Maximum Load		
Model Number	Description	Voltage	Load Type	Load	Not Ganged	End of Gang	Middle of Gang	
			Incandescent/Halogen	10 W with neutral (25 W without neutral)	1000 W	800 W	600 W	
	Wireless In-Wall		MLV Halogen	10 W	1000 VA	800 VA	600 VA	
	Dimmer		MLV LED	See Application	Note #559			
PD-10NXD PD-10NXD-XX-C <sup>8</sup>	PRO (neutral connection	120 V~	CFL/LED (120 V~ Rated) <sup>3</sup>	1 bulb <sup>3</sup>	250 W	250 W	250 W	
	required for certain load		Hi-lume <sub>®</sub> 1% 2-Wire LED drivers	1 driver	1000 W (13 drivers)	800 W (13 drivers)	600 W (13 drivers)	
	types)4		Dimmable Ballasts <sup>5</sup>	1 ballast	1000 VA	800 VA	600 VA	
			PHPM-PA/3F and GRX-TVI <sup>4</sup>	1 interface	3 interface	3 interface	3 interface	
PD-3PCL <sup>1,9</sup>	Wireless		Incandescent/Halogen	10 W	300 W	N/A	N/A	
PD-3PCL-WH-C <sup>8</sup> P-PKG1P-WH <sup>9,10</sup> P-BDG-PKG2P <sup>9,11</sup>	Plug-In Lamp Dimmer		CFL/LED (120 V~ Rated) <sup>3</sup>	1 bulb <sup>3</sup>	100 W	N/A	N/A	
		120 V~	Incandescent/Halogen	10 W	500 W	400 W	300 W	
			CFL/LED (120 V~ Rated) <sup>3, 6, 7</sup>	1 bulb <sup>3</sup>	250 W	250 W	250 W	
	Phase		MLV Halogen <sup>2, 6, 7</sup>	10 W	400 VA	400 VA	400 VA	
	Selectable		ELV Halogen	10 W	500 W	400 W	300 W	
PD-5NE PD-5NE-XX-C <sup>8</sup>	Dimmer (neutral		Hi-lume <sub>®</sub> 1% 2-Wire LED drivers <sup>6, 7</sup>	1 driver	400 W (20 drivers)	400 W (20 drivers)	400 W (20 drivers)	
	connection required)		Dimmable Ballasts <sup>5, 6, 7</sup>	1 ballast	400 VA	400 VA	400 VA	
	requirea)		PHPM-PA/3F and GRX-TVI <sup>6, 7</sup>	1 interface	3 interfaces	3 interfaces	3 interfaces	
			ELV LED	See Application	Note #559			
			MLV LED	See Application	Note #559			
PD-6WCL			Incandescent/Halogen	25 W	600 W	500 W	400 W	
PD-6WCL-XX-C <sup>8</sup> P-PKG1W-WH <sup>9,12</sup> P-BDG-PKG2W <sup>9,13</sup> P-BDG-PKG2W <sup>9,14</sup> P-BDGPRO-PKG1W <sup>9,15</sup>	Wireless In-Wall Dimmer	120 V~	CFL/LED (120 V∼ Rated) <sup>3</sup>	1 bulb <sup>3</sup>	150 W	150 W	150 W	

- Cannot be ganged.
- Need to change load type to MLV. See www.casetawireless.com/change\_phase
- 3 See bulb list at www.lutron.com/led
- 4 For PD-10NXD, a neutral connection is required for MLV loads, LED drivers, dimmable ballasts, and power modules (PHPM-PA, PHPM-3F, and GRX-TVI).
- <sup>5</sup> Compatible dimmable ballasts include Tu-Wire, Mark X, and PowerSense.
- 6 These loads are best operated using a forward-phase control. Consult www.lutron.com/bulblist to ensure the appropriate phase for bulb models used.
- SSL7 compliant when in forward-phase.
- 8 Canadian packaged product.
- 9 Available in WH only.
- 10 Kit model number. Kit includes (1) PD-3PCL-WH, and (1) PJ2-3BRL-WH-L01R (3-button with raise/lower Pico⊚ wireless control in White).
- 11 Kit model number. Kit includes (1) L-BDG2-WH (Caséta® Wireless Smart Bridge with HomeKit technology), (1) PD-3PCL-WH, (1) PJ2-3BRL-WH-L01R (3-button with raise/lower Pico® wireless control in White) and (1) L-PED1-WH (Single tabletop pedestal in White).
- 12 Kit model number. Kit includes (1) PD-6WCL-WH, (1) PJ2-3BRL-WH-L01R (3-button with raise/lower Pico⊚ wireless control in White), and (1) CW-1-WH (single-gang faceplate in White).
- 3 Kit model number. Kit includes (1) L-BDG2-WH (Caséta® Wireless Smart Bridge with HomeKit technology), (1) PD-6WCL-WH, (1) PJ2-3BRL-WH-L01R (3-button with raise/lower Pico® wireless control in White), and (1) CW-1-WH (single-gang faceplate in White).
- 14 Kit model number. Kit includes (1) L-BDG2-WH (Caséta® Wireless Smart Bridge with HomeKit technology), (2) PD-6WCL-WH, (2) PJ2-3BRL-WH-L01R (3-button with raise/lower Pico® wireless control in White), (2) L-PED1-WH (Single tabletop pedestal in White) and (2) CW-1-WH (single-gang faceplate in White).
- PRO Kit model number. Kit includes (1) L-BDGPRO2-WH (Caséta® Wireless Smart Bridge PRO with HomeKit technology), (1) PD-6WCL-WH, (1) PJ2-3BRL-WH-L01R (3-button with raise/lower Pico® wireless control in White) and (1) CW-1-WH (single-gang faceplate in White).


<b>\$\$LUTRON</b> ® SPECIFICATION®	ON SUBMITTA	١L
------------------------------------	-------------	----


Job Name:	Model Numbers:
Job Number:	

369987b 6 01.30.18

# **Ganging and Derating**

When ganging with other Switches/Dimmers in the same wallbox, derating is required. See "Load Type and Capacity" charts.






## **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369987b 7 01.30.18

# Operation



#### FASS™ - Front Accessible Service Switch

Important Notice: To service load, remove power by pulling out the FASS™ as far as possible. To restore power after servicing load, push the FASS™ back in completely.





#### LITRON. SDECIEICATION SURMITTAL

LUTRON SPECIFICATION SUBMITTAL		Page
Job Name:	Model Numbers:	
Job Number:		

369987b 8 01.30.18

# Mounting






## **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369987b 9 01.30.18

## **Dimensions**

## In-Wall Switches and Dimmers



## Plug-In Dimmer




#### **\$LUTRON**® SPECIFICATION SUBMITTAL


Page Job Name: **Model Numbers:** Job Number:

369987b 10 01.30.18

# Wiring Diagrams - Switches

## **Single Location Installation**





(continued on next page...)

<b>LUTRON</b> SPECIFICATION SUBMITTAL		Page
Job Name:	Model Numbers:	
Job Number:		

When using controls without a mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

<sup>2</sup> A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.


<sup>&</sup>lt;sup>3</sup> The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.

369987b 11 01.30.18


# Wiring Diagrams - Switches (cont.) 3-Way Installation (with mechanical switch)

Option 1

PD-5WS-DV (Load-side)



#### PD-5WS-DV (Line-side)



- Location of Caséta® Wireless In-Wall Switch and mechanical switch may be reversed.
- <sup>2</sup> A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.

(continued on next page...)

<b> \$\$LUTRON</b> ®	SPECIFICATION	SUBMITTAL
----------------------	---------------	-----------


Job Name:	Model Numbers:
Job Number:	

369987b 12 01.30.18


# Wiring Diagrams - Switches (cont.)

3-Way Installation (with mechanical switch)

Option 1 (cont.)



## PD-5ANS, PD-6ANS (Line-side)



## **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

<sup>1</sup> Location of Caséta® Wireless In-Wall Switch and mechanical switch may be reversed.

<sup>2</sup> A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.


<sup>3</sup> The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.

369987b 13 01.30.18


# Wiring Diagrams - Switches (cont.)

## 3-Way Installation (with Pico® remote controls)

Option 2: PJ2-2B-xx and wallbox mounting adapters (PICO-WBX-ADAPT)



#### PD-5ANS, PD-6ANS



- When using controls without mechanical 3-way switch, cap the blue terminal. Do not connect the blue wire to any other wiring or to ground.
- A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.
- The mechanical switch will need to be removed so the Pico<sub>®</sub> Remote Control can be installed.
- 4 The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.

(continued on next page...)

#### **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369987b 14 01.30.18

# Wiring Diagrams - Switches (cont.)


Multi-location Installation (3 or more switches control the load)

With Pico® remote controls (PJ2-2B-xx) and wallbox mounting adapters (PICO-WBX-ADAPT)

#### PD-5WS-DV



#### PD-5ANS, PD-6ANS



- 1 When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.
- 2 A LUT-MLC ensures proper function when LED, fluorescent, or ELV loads are used. Install the LUT-MLC inside a load fixture or in a separate junction box within the circuit.
- 3 The mechanical switch will need to be removed so the Pico<sub>®</sub> Remote Control can be installed.
- The red wire must be connected to the load and the black wire must be connected to Line/Hot. The switch will not work if the wires are reversed.


## **LUTRON** SPECIFICATION SUBMITTAL


Job Name:	Model Numbers:
Job Number:	

369987b 15 01.30.18

# Wiring Diagrams - Dimmers

## Single Location Installation





## **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

<sup>&</sup>lt;sup>1</sup> When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

<sup>&</sup>lt;sup>2</sup> Location of Caséta<sub>®</sub> Wireless In-Wall Dimmer PRO and mechanical switch may be reversed.

<sup>&</sup>lt;sup>3</sup> For PD-10NXD only, neutral connection optional except for MLV loads, LED drivers, and power modules (PHPM-PA, PHPM-3F, and GRX-TVI).

<sup>&</sup>lt;sup>4</sup> For PD-5NE, neutral is required.

<sup>&</sup>lt;sup>5</sup> Blue wire is only present on the PD-10NXD model.


369987b 16 01.30.18


## Wiring Diagrams - Dimmers (cont.)

#### **Multi-Location Installation**

With Pico<sub>®</sub> remote controls (PJ2-XX-XX) and wallbox mounting adapters (PICO-WBX-ADAPT)

#### PD-10NXD and PD-5NE





- 1 When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.
- Location of Caséta<sub>®</sub> Wireless In-Wall Dimmer PRO and mechanical switch may be reversed.
- For PD-10NXD only, neutral connection optional except for MLV loads, LED drivers, and power modules (PHPM-PA, PHPM-3F, and GRX-TVI).
- For PD-5NE, neutral is required.
- <sup>5</sup> Blue wire is only present on the PD-10NXD model.

## **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	


369987b 17 01.30.18

# Wiring Diagrams - Dimmers (cont.)

## 3-Way Installation


With mechanical switch

PD-10NXD



#### Installation with PHPM - Neutral required4

#### PD-10NXD and PD-5NE



## **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

<sup>&</sup>lt;sup>1</sup> When using controls without mechanical 3-way switch, cap the blue terminal. **Do not** connect the blue wire to any other wiring or to ground.

 $<sup>^{\</sup>rm 2}$  Location of In-Wall Dimmer and mechanical switch may be reversed.

<sup>&</sup>lt;sup>3</sup> Neutral connection optional except for MLV loads, LED drivers, and power modules (PHPM-PA, PHPM-3F, and GRX-TVI).

<sup>&</sup>lt;sup>4</sup> See Lutron<sub>®</sub> P/Ns 369356 and 369355 for additional wiring diagrams.


<sup>&</sup>lt;sup>5</sup> Blue wire is only present on the PD-10NXD model.

369987b 18 01.30.18

# Wiring Diagrams - Dimmers (cont.)


# Installation with GRX-TVI - Neutral required1

#### PD-10NXD and PD-5NE



## Installation with Hi-lume 1% 2-wire LED Drivers - Neutral required

#### PD-10NXD and PD-5NE



Note: For more information on Hi-lume<sub>®</sub> 1% 2-wire LED Drivers, see www.lutron.com

## **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	

<sup>&</sup>lt;sup>1</sup> See Lutron<sub>®</sub> P/N 369247 for additional wiring diagrams.

 $<sup>^{2}</sup>$  Blue wire is only present on the PD-10NXD model.

369987b 19 01.30.18

# **Colors and Finishes**

## **Gloss Finishes**



Due to printing limitations, colors and finishes shown cannot be guaranteed to perfectly match actual product colors.

PowerSense is a registered trademark of Osram Sylvania.

## **LUTRON** SPECIFICATION SUBMITTAL

Job Name:	Model Numbers:
Job Number:	